



Certificate No:  
**TAE000047S**

# TYPE APPROVAL CERTIFICATE

---

## This is to certify:

**That the Frequency Converter**

with type designation(s)  
**VS10, VS30-23, VS30-40, DSV15, DSV35**

Issued to  
**CG Drives & Automation Germany GmbH**  
**Wernigerode, Sachsen-Anhalt, Germany**

is found to comply with  
**DNV GL rules for classification – Ships, offshore units, and high speed and light craft**

## Application :

---

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

Issued at **Hamburg** on **2021-08-09**

This Certificate is valid until **2026-08-08**.

DNV local station: **Essen**

for **DNV**

Approval Engineer: **Thomas Hartmann**

---

**Arne Schaarmann**  
**Head of Section**

---

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



## Product description

Adjustable speed semi-conductor converters for motor drives with a power ranges from 0.25 kW up to 22 kW.

### General performance data

Degree of protection IP	20
Pollution degree	2
Overvoltage Category	III
Nominal Input frequency	50/60 Hz
Upstream protection	Fuses or circuit-breaker as per maker's instructions
Output frequency	0...599 Hz
Cooling method (power circuits)	Forced Air

### Model particulars

Type	Rated power	Nominal voltage	Connection	Supply voltage range	Rated current at nominal voltage
VS10	0,25-2,2 kW	230 V	1-phase	190–240 V	1,7-9,6 A
VS30-23	0,25-2,2 kW	230 V	1-/3-phase	190–240 V	1,7-9,6 A
VS30-40	0,37-2,2 kW	400 V	3-phase	380–480 V	1,3-5,6 A
DSV15	0.25-2.2 kW	230 V	1-phase	190–240 V	1.7-9.6 A
DSV35	0.37-22 kW	400 V	3-phase	380–480 V	1.3-47.0 A

## Application/Limitation

Converters to be installed in a cubicle/ switchboard in accordance with "Mounting and switch on instruction"

Location classes according to CG-0339:

Temperature class	B <sup>1)</sup>
Vibration class	A
Humidity class	A <sup>2)</sup>
EMC class	A <sup>3)</sup>

1) Maximum ambient temperature depends on switching frequency and model. Output current de-rating as per maker's instructions apply.

2) Installation at locations where special precautions to avoid condensation are taken or anti-condensation measures are required.

3) Converters with EMC classed C2 or C3 according to IEC 61800-3 can be installed in "special distribution zone" and "general power distribution zone" in accordance with IEC 60533 provided precautions are taken to attenuate these effects on the distribution system, so the safe operation is assured. The use of external filters to meet IEC 61800-3 is required.

Guidance Note:

The EMC measures should be derived from an EMC analysis and plan in accordance with IEC 60533 Annex B and /or IEC 61800-3 Annex E.

End of Guidance note

## Type Approval documentation

### Tests carried out

Electrical and performance tests according to IEC 61800-5-1, EMC according 61800-3, Environmental and Vibration tests according to CG-0339 (2019)

## Marking of product



Job Id: **262.1-031185-1**  
Certificate No: **TAE000047S**

CG - Type designation - Power – Voltage

### **Place of Production**

Customer NPS-ID 10691351

### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE